

Office of The Chief Medical Officer, Ghaziabad

Ref.No. DSO/IDSP/2025/ 807

Dated:- 17-07-2025

WATER TEST REPORT

ADDRESS:- L.K INTERNATIONAL SCHOOL, KAZIPURA NEAR JAAT CHOWK, NH-24, GHAZIABAD.

PREVIOUS SAMPLE COLLECTION DATE	SAMPLE COLLECTION AREA	SAMPLE WATER WAS BEING USED	SAMPLE ID	RESULT
04-07-2025	GROUND FLOOR	DRINKING	4896	Unsatisfactory
04-07-2025	FIRST FLOOR	DRINKING	4897	Unsatisfactory
04-07-2025	OVER HEAD	DRINKING	4898	Unsatisfactory

No of sample collected : 03

SAMPLE COLLECTION DATE	SAMPLE COLLECTION AREA	SAMPLE WATER WAS BEING USED	SAMPLE ID	RESULT
15-07-2025	GROUND FLOOR RO WATER	DRINKING	4981	Satisfactory
15-07-2025	FIRST FLOOR RO WATER	DRINKING	4982	Satisfactory
18-07-2025	OVER HEAD	DRINKING	4983	Satisfactory

Test Result

H₂S Water test kit : Negative (-Ve) after 24-48 hrs Incubation

Comments:-

H₂S water test kit report - ve reflects that water is free from Collforms Organism.

Recommendation:

Given water safe for drinking purpose.

➤ This Satisfactory report/result is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand cancelled on proof.

➤ Validity upto one year.

For L.K International School
Secretary

Municipal
L.K. International School
Affiliated to CBSE, New De
Vide Code No. 2130905
Ghaziabad

(Dr R.K Gupta)

District Public Health Expert
District Surveillance Officer
District Public Health Expert
District Ghaziabad

Lab Technician
ICSP Lab
Ghaziabad